





Detached Bungalow - 1961 - Cavity wall construction - 108m² (1157ft²)



Oughterard, County Galway

Existing Building Details					
	Building Elements	Insulation Thickness (mm)	U-Value (W/m ² .K)		
Walls	300mm Cavity Wall, Partially Filled	50mm	0.55		
Roof	Pitched Roof insulated at ceiling	50mm-100mm	0.68		
Floor	Solid Floor	Unknown	0.84		
Windows	Double Glazed Air filled	N/A	2.7-3.1		
Doors	Glazed Door	N/A	3		

Existing Heating Characteristics				
	Energy	Efficiency (%)		
Primary Heating System	Oil boiler, primary pipework uninsulated	Oil	75%-80%	
Secondary Heating System	Stove	Multi fuel	70%	
Domestic Hot Water	Heated with Oil Boiler & Electric immersion			
Cylinder Factory cylinder Insulated (30mm)				
Controls	Timer, No TRV			

	Domestic Retrofit Guidelines (Step by Step)				Carbon Emissions (CO2) (kgCO2/m²/yr)	Building Energy Rating (BER)
	Energy Efficient Measures		Target U-Value (W/m2.K)	Current Usage (414.81)	Current Emissions (103.89)	Current BER (F)
1	Roof insulation	Loftwool Insulation top-up to achieve 300mm- 400mm across all roof area.	0.13 - 0.16	378.68	94.6	E2
2	Cavity Wall Insulation (CWI)	Pump Existing cavity with a bondeed bead insulation	0.30 - 0.35	236.02	57.92	D1
3		Install Wall Insulation (internal or External), thickness 50mm-100mm	0.18 - 0.21	223.06	54.59	C3
4	Floor Upgrade	Insulate solid floor with rigid insulation	0.15 - 0.18	165.5	39.79	C1
5	Window/Door Upgrade	Replace existing glazing with Double/Triple glazed,(low E) units	1.1 - 1.4	148.5	35.4	В3
6	Lighting	Install energy efficient light bulbs (LEDs)	N/A	143.04	34.58	В3
7	Heating Upgrade (Primary)	Air to water heat pump, 4-6kW, two separate heating zones and controller.	N/A	62.05	14.55	A3
8	Renewables	Install 1.2 kWp Solar PV system	N/A	44.71	10.9	A2
9						
10						




ENERGY AUDIT REPORT









	Estimated Costs Summary				
	Measures	Estimated Costs (€/m ²)	Estimated Total Costs (€)		
1	Roof Upgrade	10 - 15	€ 1,290		
2	Cavity Wall upgrade	7 - 10	€ 1,382		
3	Wall Insulation	70-100	€ 11,751		
4	Floor Upgrade	80 - 100	€9,671		
5	Window/Door upgrade	250 - 350	€ 7,041		
6	Lighting	20/fitting	€ 180		
7	Heating Upgrade (Primary)	12,500 (System)	€ 12,500		
8	Solar PV	2,200 (1.2 kWp System)	€ 2,200		
9	Demand Controlled Ventilation	3,000 (System)	€ 3,000		
10	0	0	€0		
	Total	€ 49,015			
	Total Cost to Homeowner including 35% Grant funding	€ 31,860			

Savings Summary				
BER Rating	Energy Savings (kWh/m²/yr)	Energy Savings (kWh/yr)	Cost Savings (€/yr)	Simple Payback, including 35% Grant Funding (years)
A2	370.1	39,771	€ 1,989	16

Audit site visit completed on 14/11/2019, Audit report edited on 10/12/2019